



TEMP. RANGE:  
PRESS. RANGE:  
DATE May 3-2011  
CMR GCC-425

BARCHARD ENGINEERING LTD.  
ALBERTA MEASUREMENT SERVICE LTD.  
GAS MEASUREMENT

Dead Weight Reading for Test Mile Post 188  
 AFE 410A110558 - May 3 - 2011

9:50 am	571	PSI	leak test
10:00 am	1054	PSI	leak test
10:14 am	1328	PSI	Test on
10:30 am	1326	PSI	
10:45 am	1324.9	PSI	
11:00 am	1324.7	PSI	
11:15 am	1327.5	PSI	
11:30 am	1330.	PSI	- Bleed down to 1327 temp Su
11:45 am	1332.1	PSI	- Bleed down to 1327 "
12:00 Noon	1328.6	PSI	-
12:15	1330.8	PSI	- Bleed down 1327
12:30	1329.8	PSI	- Bleed down 1327
12:45	1330.6	PSI	- Bleed down 1327
1:00	1331.4	PSI	- Bleed down 1327
1:15	1332.1	PSI	- Bleed down 1327
1:30	1332.4	PSI	- Bleed down 1327
1:45	1331.6	PSI	- Bleed down 1327
2:00	1332.4	PSI	- Bleed down 1327
2:15	1330.2	PSI	- Bleed down to $\phi$ test off

~~XXXXXXXXXX~~